



Lloyd's
Register

Notified Body authorised by the MCA



Maritime &
Coastguard
Agency

EC TYPE EXAMINATION (MODULE B) CERTIFICATE

This is to certify that:

LLOYD'S REGISTER VERIFICATION LIMITED (LRV), designated as a "notified body" under the terms of the Merchant Shipping (Marine Equipment) Regulations 2016 (S.I. 2016 No.1025), did undertake the relevant type approval procedures for the equipment identified below which was found to be in compliance with the essential Fire protection equipment requirements of Marine Equipment Directive (MED) 2014/90/EU and Commission Implementing Regulation (EU) 2018/773 indicating design, construction and performance requirements and testing standards for marine equipment, subject to any conditions in the Design Appraisal Document attached hereto.

Manufacturer (Applicant)	Integrated Fire Protection Pvt. Ltd
Address	60A Pandit Madan Mohan Malabya Sarani Chakraberia Road (North) Kolkata - 700020 West Bengal India
Reference	Regulation (EU) 2018/773
Regulation Item (No & Item designation)	MED/3.59 - EXPANSION FOAM FOR FIXED FIRE EXTINGUISHING SYSTEMS FOR CHEMICAL TANKERS
Product Type	FOAM CONCENTRATE
Product Description	Fire Extinguishing Low-expansion Type A (Multi-purpose) Alcohol Resistant Fluoroprotein (AR-FP) Foam Concentrates - Types "IFP AR-FP PLATINUM 3/3 ^{CE} " and "IFP AR-FP PLATINUM 3/6 ^{CE} " for use on hydrocarbon and polar solvent fires.
Specified Standard	IMO MSC.1/Circ.1312, IMO MSC.1/Circ.1312 Corrigendum 1

The attached Design Appraisal Document (schedule) forms part of this certificate.

This certificate remains valid unless cancelled or revoked, provided the conditions in the attached schedule are complied with and the equipment remains satisfactory in service.

Date of issue 14 May 2019 Expiry date 13 May 2024

Certificate No. MED 1950075

Signed

Sheet No. 1 of 4

Name

S. Abraham

For and on behalf of Lloyd's Register Verification
LRV EC Distinguishing No. 0038

Note:

This certificate is issued under the authority of the MCA.

This certificate is not valid for equipment; the design or manufacture of which has been varied or modified from the specimen tested. The manufacturer should notify the notified body named on this certificate of any modification or changes to the equipment in order to obtain a valid Certificate.

Lloyd's Register Verification Limited (Reg. no. 4929226) is a limited company registered in England and Wales. Registered office: 71 Fenchurch Street, London, EC3M 4BS, UK. A subsidiary of Lloyd's Register Group Limited.

Lloyd's Register Group Limited, its affiliates and subsidiaries and their respective officers, employees or agents are, individually and collectively, referred to in this clause as the 'Lloyd's Register'. Lloyd's Register assumes no responsibility and shall not be liable to any person for any loss, damage or expense caused by reliance on the information or advice in this document or howsoever provided, unless that person has signed a contract with the relevant Lloyd's Register entity for the provision of this information or advice and in that case any responsibility or liability is exclusively on the terms and conditions set out in that contract.



Lloyd's
Register

Lloyd's Register Verification Limited

71 Fenchurch Street, London, EC3M 4BS

Telephone 020 7423 2416 Fax 020 7423 2053

Email med@lr.org

Page 2 of 4
Document number MED 1950075
Issue number 1

DESIGN APPRAISAL DOCUMENT

Date 14 May 2019	Quote this reference on all future communications UKITSO/FIRE/TA/JE/SA/WP34272302
---------------------	--

ATTACHMENT TO EC TYPE EXAMINATION (MODULE B) CERTIFICATE No. MED 1950075

The undernoted documents have been appraised for compliance with the relevant requirements of International Conventions and European Union legislation for the EC Type Examination of Marine Equipment for use on Merchant Ships Registered in the European Economic Area.

This Design Appraisal Document (schedule) forms part of the Certificate.

APPROVAL DOCUMENTATION

Advance Firetec and Research Lab Pvt. Ltd (AFTRL), B-3 Mangolpuri Industrial Area, Phase-II, Delhi 110034, India; Test Reports No. 669 and 670, both dated 4th April 2018 and Supplementary Test Reports for Small Scale Reference Fire Tests No: 669 (S) and No: 670 (S), both dated 14 November 2018.

CONDITIONS OF CERTIFICATION

- Types: "IFP AR-FP PLATINUM 3/3C6" and "IFP AR-FP PLATINUM 3/6C6" are Type A (Multi-purpose) Alcohol Resistant Fluoroprotein (AR-FP) Low-expansion foam concentrates for use on hydrocarbon fires and polar solvent/alcohol-based fires*, with the following essential characteristics (determined based on testing with seawater in accordance with IMO MSC.1/Circ.1312)

	"IFP AR-FP PLATINUM TYPE 3/3C6"	"IFP AR-FP PLATINUM TYPE 3/6C6"
Usage concentration	3% for both hydrocarbon and polar solvent fires	3% for hydrocarbon and 6% for polar solvent fires
Expansion ratio	7.67	7.50 (3%), 8.1 (6%)
Drainage time (25%)	2 minutes 50 seconds	2 minutes 24 seconds (3%) & 3 minutes 55 seconds (6%)
Volumic mass density (g/ml)	1.13	1.13
Kinematic viscosity (mm ² /s or cSt)	23.18	22.26
Sedimentation (%)	0.12	0.13
pH value	7.03	7.2
Freezing temperature (°C)	-6	-6
Storage temperature range (°C)	Above -6 up to 49	Above -6 up to 49

*The above foam concentrates demonstrated satisfactory fire performance when tested separately with n-heptane (representing hydrocarbon fuels) and isopropyl alcohol and acetone (representing polar solvent fuels) in accordance with IMO MSC.1/Circ.1312

- To be used with separately approved fixed or mobile low expansion foam fire extinguishing systems
- It is to be confirmed that the IMO MSC.1/Circ.1312 test standard is acceptable for the project and applications envisaged



Lloyd's
Register

Lloyd's Register Verification Limited

71 Fenchurch Street, London, EC3M 4BS

Telephone 020 7423 2416 Fax 020 7423 2053

Email med@lr.org

Page 3 of 4
Document number MED 1950075
Issue number 1

DESIGN APPRAISAL DOCUMENT

Date 14 May 2019	Quote this reference on all future communications UKITSO/FIRE/TA/JE/SA/WP34272302
---------------------	--

ATTACHMENT TO EC TYPE EXAMINATION (MODULE B) CERTIFICATE No. MED 1950075

4. This certificate only approves the fire performance characteristics of the foam concentrate in accordance with IMO MSC.1/Circ.1312. The use of certain foam concentrates may also be subject to additional requirements, including environmental regulations, depending on the projects where they are to be used. Therefore, the suitability of the foam concentrate for each application must also be confirmed at the design stage by the Project Plan Approval authority
5. Protein-based (P) Alcohol Resistant (Type A) foam concentrates should be subjected to the following tests by independent laboratories or authorised service suppliers acceptable to Lloyd's Register or the relevant Administration:
 - 5.1 Annual small-scale reference fire testing to EN 1568-4 Annex I as specified in Annex 3.14 of IMO MSC.1/Circ.1312, to demonstrate that the fire control, extinguishment and burnback times do not exceed the following values obtained in the original small-scale fire tests conducted to the above standard, as evidence of manufacturing consistency of the foam concentrates:

	"IFP AR-FP PLATINUM TYPE 3/3 ^{C6} "	"IFP AR-FP PLATINUM TYPE 3/6 ^{C6} "
90% Fire Control Time	40 seconds	56 seconds
99% Fire Control Time	47 seconds	60 seconds
Complete Extinction Time	55 seconds	73 seconds
Burn back time	9 minutes	7 minutes

- 5.2 Chemical Stability test in accordance with Annex 4.7 of IMO MSC.1/Circ.1312 prior to delivery to the ship and annually thereafter and
 - 5.3 All other periodical tests in accordance with Annex 4 and 5 of IMO MSC.1/Circ.1312 not more than 3 years after being supplied to the ship and annually thereafter.
6. The storage container should be compatible with the foam concentrates throughout the service life of the foam
7. Each product is to be supplied with its manual for application, use, transport, storage and maintenance.
8. A Batch Certificate should be provided with each delivery, with a declaration of the main characteristics of Sedimentation, pH Value, Expansion Ratio, Drainage Time and Volumic Mass, by the manufacturer and will be the basis for the periodical testing
9. Chemical composition of foam is to be maintained in production in accordance with originally tested composition formula
10. Production items are to be manufactured in accordance with a quality control system which shall be maintained to ensure that items are of the same standard as the approved prototype
11. The certificate holder is solely responsible for the products supplied under this Certificate and to ensure that their products, whether manufactured by themselves or their licensee manufacturers if agreed by Lloyd's Register, are fully compliant with the applicable statutory regulations and designed and manufactured to the same quality and specifications as the prototype tested, including components that are designed and manufactured by third parties



Lloyd's
Register

Lloyd's Register Verification Limited

71 Fenchurch Street, London, EC3M 4BS

Telephone 020 7423 2416 Fax 020 7423 2053

Email med@lr.org

Page 4 of 4
Document number MED 1950075
Issue number 1

DESIGN APPRAISAL DOCUMENT

Date 14 May 2019	Quote this reference on all future communications UKITSO/FIRE/TA/JE/SA/WP34272302
---------------------	--

ATTACHMENT TO EC TYPE EXAMINATION (MODULE B) CERTIFICATE No. MED 1950075

12. Production items of the subject equipment are to be manufactured in accordance with either an approved Production Quality Assurance system (Module D), a Product-Quality assurance system (Module E) or a Product Verification Process (Module F). The wheelmark cannot be affixed to the product until a conformity assessment module is in place
13. Each item, batch or lot of the equipment is to be issued with a "Declaration of Conformity" and have the "Mark of Conformity" affixed after a conformity assessment module is in place

PLACE OF PRODUCTION

Integrated Fire Protection Pvt. Ltd
Rajbari Para
Jalpaiguri 735101
West Bengal
India



Saji Abraham
Senior Specialist
Fire & Safety, Statutory Discipline Team
UK&I Technical Support Office, Marine & Offshore
For and on behalf of Lloyd's Register Verification
LRV EC Distinguishing No. 0038